

## CENTRAL INTELLIGENCE AGENCY

S-E-C-R-E-T

25X1

## REPORT

DATE DISTR.

14 December 1955

25X1

NO. OF PAGES

22

REQUIREMENT NO.

RD

## REFERENCES

25X1

This is UNEVALUATED Information

25X1

**SOURCE EVALUATIONS ARE DEFINITIVE. APPRAISAL OF CONTENT IS TENTATIVE.**

2. This power station, known before the last war as Pommerenzdorf, is near Szczecin(Stettin). Originally it was supplied with power plant equipment obtained for Germany

25X1

the original station was

3. An originally equipped, the factory had a total output of 200 MW which was obtained from eight boilers driving 4 - 50-MW generators. During the last war, the station was stripped by the Germans and has been out of operation since that date. It has now been decided by the Polish authorities to re-equip the station so that it will again have a final capacity of 200 MW obtained from 4 - 50-MW generators. However, there will only be four boilers, each having a capacity of 200-ton/hour evaporation, each boiler being coupled to a generator; the old system was two 100-ton/hour boilers coupled to one generator.

~~S-E-C-R-E-T~~

25 YEAR RE-REVIEW

25X1

(Note: Washington distribution indicated by "X"; Field distribution by "#")

S-E-C-R-E-T

25X1

4. The re-equipment of the power station will be carried out in two stages; for the first stage only two 50-MW generators and two 200-ton/hour boilers will be installed. The power will be finally taken by six 110-KV transmission lines, but for this stage only four 110-KV lines will be provided. A system of open cooling will be employed with cooling water at 12° Centigrade. The power station will burn Upper Silesian dust coal. Elektrim and Energoprojekt have both stressed the need for very high efficiency and provision has therefore been made for a high-temperature reheating system to give an official over-all efficiency of about 89%. The original two-meter-thick concrete roof and the old foundations are still intact and will not be moved. This will give rise to certain technical difficulties as the head room available, approximately 23.4 meters, is extremely small for the installation of 200-ton/hour boilers. To overcome this difficulty the new boilers will be turned through 90° from the position of the former 110-ton/hour boilers and a multi-pass arrangement of boiler tubes and heating surfaces will be used.

25X1

- 2 -

S-E-C-R-E-T

25X1